Pt. 72, App. B

40 CFR Ch. I (7-1-13 Edition)

TABLE A-1—SO₂EMISSION AVERAGING PERIODS AND ANNUALIZATION FACTORS

	Annualization factor Scrubbed Unscrubbed		
Definition			
	Unit	Unit	
Oil/gas unit	1.00	1.00	
<=1 day	0.93	0.89	
1 week	0.97	0.92	
30 days	1.00	0.96	
90 days	1.00	1.00	
1 year	1.00	1.00	
Not specified	0.93	0.89	
At all times	0.93	0.89	
Coal unit: No Federal limit or limit			
unknown	1.00	1.00	

APPENDIX B TO PART 72—METHODOLOGY FOR CONVERSION OF EMISSIONS LIMITS

For the purposes of the Acid Rain Program, all emissions limits must be expressed

in pounds of SO_2 per million British Thermal Unit of heat input (lb/mmBtu).

The factor for converting pounds of sulfur to pounds of SO2 is based on the molecular weights of sulfur (32) and SO₂ (64). Limits expressed as percentage of sulfur or parts per million (ppm) depend on the energy content of the fuel and thus may vary, depending on several factors such as fuel heat content and atmospheric conditions. Generic conversions for these limits are based on the assumed average energy contents listed in table A-2. In addition, limits in ppm vary with boiler operation (e.g., load and excess air); generic conversions for these limits assume, conservatively, very low excess air. The remaining factors are based on site-specific heat rates and capacities to develop conversions for Btu per hour. Standard conversion factors for residual oil are 42 gal/bbl and 7.88 lbs/gal.

TABLE B-1—CONVERSION FACTORS

[Emission limits converted to lbs SO₂/MMBtu by multiplying as below]

Unit measurement	Plant fuel type			
	Bituminous coal	Subbitu- minous coal	Lignite coal	Oil
Lbs sulfur/ MMBtu	2.0	2.0	2.0	2.0
% sulfur in fuel	1.66	2.22	2.86	1.07
Ppm SO ₂	0.00287	0.00384		0.00167
Ppm sulfur in fuel				0.00334
Tons SO ₂ /hour	2,000,000/	(HEATRATE*S	UMNDCAP	*capacity
		(factor)	1	. ,
Lbs SO ₂ /hour	1,000/(HEAT	RATE*SUMNÉ	CAP*capac	city factor) 1

¹In these cases, if the limit was specified as the "site" limit, the summer net dependable capability for the entire plant is used, otherwise, the summer net dependable capability for the unit is used. For units listed in the NADB, "HEATRATE" shall be that listed in the NADB under that field and "SUMNDCAP" shall be that listed in the NADB under that field. For units not listed in the NADB, "HEATRATE" is the generator net full load heat rate reported on Form EIA–860 and "SUMNDCAP" is the summer net dependable capability of the generator (in MWe) as reported on Form EIA–860.

TABLE B-2—ASSUMED AVERAGE ENERGY

0020				
Fuel type	Average heat content			
Bituminous Coal Subbituminous Coal Lignite Coal	18 MMBtu/ton.			
Residual Oil				

APPENDIX C TO PART 72—ACTUAL 1985 YEARLY SO₂ Emissions Calculation

The equation used to calculate the yearly SO_2 emissions (SO2) is as follows:

SO2 = (coal SO₂ emissions) + (oil SO₂ emissions) (in tons)

If gas is the only fuel, gas emissions are de-

faulted to 0.

Each fuel type SO₂ emissions is calculated

Each fuel type SO_2 emissions is calculated on a yearly basis, using the equation:

fuel SO₂ emissions (in tons) = (yrly wtd. av. fuel sulfur %) \times (AP-42 fact.) \times (1-scrb.

effic. %/100) × (units conver. fact.) × (yearly fuel burned)

For coal, the yearly fuel burned is in tons/yr and the AP-42 factor (which accounts for the ash retention of sulfur in coal), in lbs SO_2 ton coal, is by coal type:

Coal type	AP-42 factor
Bituminous, anthracite Subbituminous Lignite	39 lbs/ton 35 30

For oil, the yearly fuel burned is in gal/yr. If it is in bbl/yr, convert using 42 gal/bbl oil. The AP-42 factor (which accounts for the oil density), in lbs SO_2 /thousand gal oil, is by oil type:

Oil type	AP-42 factor
Distillate (light)	142 lbs/1,000 gal 157